INTERIOR DRYWALL QUALITY CONTROL CHECKLIST PRIOR TO ONE-SIDE AND DOUBLE-UP

	: Temperature: :	Project #:	
Project Manager	:	· · · · · · · · · · · · · · · · · · ·	
Floor / Area Worked			
Prior to one-side		<u>Foreman</u>	Q. C. <u>Sign-off</u>
1.	Confirm electrical boxes are not protruding beyond stud plane.		
2.	Confirm MEP strapping not bulging beyond stud plane.		
3.	Confirm MEP strapping does not overlap and cause bulging.		
4.	Confirm all framing; backing and HMD have not been damaged.		
5.	Confirm framing and MEP installation is signed-off for close up.		
6.	Confirm framing and backing QC forms are signed-off.		
One-side			
1.	Confirm HM doors are plumb and true.		
2.	Confirm correct fasteners are spaced per plans and specs.		
3.	Confirm joints are butted per plans and specs.		
4.	Confirm control joints are installed per plans and specs.		
Double-up			
1.	Confirm track cavities are cleaned.		
2.	Confirm wall insulation installed where required.		
3.	Confirm joints are butted per plans and specs.		
4.	Confirm control joints are installed per plans and specs.		
5.	Confirm vertical board joints are staggered 1-stud bay minimum both sides of rated walls.	at	

Comments:

Foreman's Signature

Quality Control Sign-Off

Inspection Request #

